

DESIGN CRITERIA

1. Related Sections: See related Division 10 and Division 22 Design Criteria.
2. This Section includes floor mounted, overhead braced, textured stainless steel toilet compartments. If required in plan layout, provide matching wall mounted urinal screens. Size of urinal screens shall be 18" deep x 42" high, with top of screen set 58" above finish floor.
3. Layout of toilet compartments shall be in accordance with applicable provisions in the U.S. Architectural & Transportation Barriers Compliance Board's "Architectural Barriers Act (ABA) Accessibility Guidelines for Buildings and Facilities" and ICC/ANSI A117.1 guidelines.
4. Layout of room shall not permit direct view (or mirror reflected view) into toilet rooms. Current DeCA criteria requires that all multiple-use restroom doors (and locker room doors if connected) swing outward from the restroom or locker room for sanitation reasons. Single-use family restroom doors may swing into the rooms as these doors have locksets with handles.
5. Coordinate placement of toilet accessories, both partition mounted and wall mounted, to avoid conflicts with toilet compartment door swings.
6. Coordinate toilet compartment locations with other design disciplines (i.e., electrical receptacles, wall thermostats, radiant heaters, etc.). Contract Documents shall clearly identify requirement for wood blocking (or other material) within metal stud framed walls for proper attachment and support of toilet compartments.
7. Show dimensioned elevations on drawings. Indicate accessory locations where cutouts and reinforcements are required. Indicate pilaster, door, panel, and screen heights.

END OF SECTION