



DESIGN COLD STORAGE ROOMS WITH MINIMUM 2" WIDE AIR SPACE BETWEEN COLD STORAGE ROOM WALL PANELS AND ADJACENT WALL SURFACES. WHEN COLD STORAGE ROOM IS LOCATED ADJACENT TO EXTERIOR WALL OF BUILDING, CONSIDER INCREASING WIDTH OF AIR SPACE.

PROVIDE STAINLESS STEEL CLOSURE STRIPS AT ALL LOCATIONS WHERE AIR SPACE IS EXPOSED TO VIEW.

DATE	DEFENSE COMMISSARY AGENCY DIRECTORATE OF ENGINEERING FORT LEE, VIRGINIA - LACKLAND AFB, TEXAS		DESIGN STANDARD
JUN 2022	TITLE COLD STORAGE ROOMS AIR SPACE CLOSURE DETAILS	REF.	132126-05
		REV.	