



NOTES:

1. REFERENCE THIS DETAIL WHEN DIRECTED FROM DECA AS AN ALTERNATIVE HVAC OPTION.
2. PROVIDE A VAPOR SEALED ENVELOPE AROUND THE SALES AREA. PAY PARTICULAR ATTENTION TO SEALING THE SALES AREA REAR WALL TO THE ROOF DECK.
3. ANTI-SMUDGE DEVICES SHALL BE PROVIDED UNLESS PERFORATED PLATE DIFFUSERS ARE USED.
4. INSTALL DESTRATIFICATION FANS ABOVE REFRIGERATED AISLES.
5. HEATING OF ENTRY/EXIT VESTIBULES SHALL BE AS STATED IN CRITERIA SECTION 230500.

LEGEND:

- ◆ DOOR GRILLE
- ⊠ SUPPLY AIR DIFFUSER
- ⊡ RETURN AIR GRILLE
- ⊙_S RMCS SENSOR

RMCS TEMPERATURE AND HUMIDITY SENSOR. MOUNT 1'-0" ABOVE GONDOLA SHELVING WHEN MOUNTED ON COLUMNS.

SALES AREA HVAC CONCEPT PLAN - DISTRIBUTED HVAC OPTION

DATE JUN 2022	DEFENSE COMMISSARY AGENCY DIRECTORATE OF ENGINEERING FORT LEE, VIRGINIA - LACKLAND AFB, TEXAS		DESIGN STANDARD
	TITLE OPTIONAL SALES AREA HVAC CONCEPT PLAN	REF.	230500-03B
	REV.		