



LEGEND:

- ◆ DOOR GRILLE
- ⊠ SUPPLY AIR DIFFUSER
- ⊞ RETURN AIR GRILLE
- ⊙ RMCS SENSOR

NOTES:

1. PROVIDE A VAPOR SEALED ENVELOPE AROUND THE SALES AREA. PAY PARTICULAR ATTENTION TO SEALING THE SALES AREA REAR WALL TO THE ROOF DECK.
2. ANTI-SMUDGE DEVICES SHALL BE PROVIDED UNLESS PERFORATED PLATE DIFFUSERS ARE USED.
3. DO NOT RETURN AIR UNDER CASES. UTILIZE SIDEWALL DEVICES PREFERABLY IN DISCRETE LOCATIONS. DO NOT INTERFERE WITH DECOR.
4. INSTALL DESTRATIFICATION FANS ABOVE REFRIGERATED AISLES.
5. HEATING OF ENTRY/EXIT VESTIBULES SHALL BE AS STATED IN CRITERIA SECTION 230500.

SALES AREA HVAC CONCEPT PLAN

DATE JUN 2022	DEFENSE COMMISSARY AGENCY DIRECTORATE OF ENGINEERING FORT LEE, VIRGINIA - LACKLAND AFB, TEXAS TITLE SALES AREA HVAC CONCEPT PLAN	DESIGN STANDARD 230500-03
		REF.
		REV.