



NOTES:

1. SEPARATE SYSTEM FOR CASHIER'S AREA.
2. PROVIDE SEPARATE PERIMETER HEATING SYSTEM FOR LOCATIONS WITH A 97.5% WINTER DESIGN TEMP. LESS THAN 0° C (32° F) db.
3. PROVIDE SUITABLE ACCESS AND MAINTENANCE WORKING PLATFORMS.

LEGEND:

- ☒ SUPPLY AIR DIFFUSER
- ☒ RETURN AIR GRILLE
- ☒ EXHAUST AIR GRILLE
- Ⓧ RMGS SENSOR

CASHIER'S AREA

<p>DATE</p> <p>JUN 2022</p>	<p>DEFENSE COMMISSARY AGENCY DIRECTORATE OF ENGINEERING FORT LEE, VIRGINIA - LACKLAND AFB, TEXAS</p> <p>TITLE</p> <p>CASHIER'S AREA HVAC CONCEPT PLAN</p>	<p>DESIGN STANDARD</p> <p>230500-04</p>
	<p>REF.</p> <p>REV.</p>	