

FISH MARKET EXHAUST FAN






ROTISSERIE OVEN HOOD AND EXHAUST FAN. PROVIDE TYPE I FIRE SUPPRESSION SYSTEM.

AROMA TRANSFER FAN, INLINE

DOUBLE WALL, POSITIVE PRESSURE, OVEN VENT, UP TO EXHAUST FAN ON ROOF ABOVE

ROOFTOP HVAC UNIT OR SPLIT SYSTEM FAN COIL UNIT IN ADJACENT MECHANICAL SPACE

LEGEND:

-  SUPPLY AIR DIFFUSER
-  RETURN AIR GRILLE
-  EXHAUST AIR GRILLE
-  RMCS SENSOR
-  DOOR UNDERCUT
-  REINFORCED DOOR GRILLE

NOTES:

1. BAKERY AROMA TRANSFER FAN SHALL BE CONTROLLED BY A 4-HOUR SPRING TIMER.
2. SUITABLE ACCESS AND MAINTENANCE WORKING PLATFORM SHALL BE PROVIDED.

**BAKERY / DELI AREA  
HVAC CONCEPT PLAN**

DATE	DEFENSE COMMISSARY AGENCY DIRECTORATE OF ENGINEERING FORT LEE, VIRGINIA - LACKLAND AFB, TEXAS	DESIGN STANDARD
JUN 2022	TITLE <b>BAKERY / DELI AREA HVAC CONCEPT PLAN</b>	230500-05
		REF.
		REV.