








LEGEND:

-  EXHAUST GRILLE
-  EXHAUST FAN
-  VOLUME DAMPER
-  WALL GRILLE (SECURITY TYPE)
-  DOOR UNDERCUT
-  DOOR GRILLE, REINFORCED
-  THERMOSTAT

NOTES:

1. LOCATION BASED ON PROPER AIRFLOW REQUIREMENTS.
2. SEE CRITERIA FOR MINIMUM EXHAUST REQUIREMENTS.
3. WG TO BE SIZED FOR VENTILATION AIRFLOW REQUIRED.
4. EXHAUST FANS INTERLOCKED WITH LIGHT SWITCHES AND THERMOSTAT SO FAN WILL ONLY RUN WITH LIGHTS ON AND CALL FOR COOLING.

CONTROLLED/SENSITIVE STORAGE AREAS

DATE JUN 2022	DEFENSE COMMISSARY AGENCY DIRECTORATE OF ENGINEERING FORT LEE, VIRGINIA - LACKLAND AFB, TEXAS		DESIGN STANDARD 230500-09
	TITLE CONTROLLED / SENSITIVE STORAGE AREAS	REF.	
		REV.	