



NOTES:

1. ADD POWER CONDITIONERS WHERE NECESSARY FOR STABLE FUNCTION
2. SEE DESIGN STANDARD 265100-01 FOR CONTINUATION
3. STAGING AND RECEIVING LIGHTING IS TO BE ENERGIZED CONTINUOUSLY WITH LOCAL OCCUPANCY SENSOR. DO NOT CONNECT TO RMCS.
4. POWER LIGHTS NORMALLY CLOSED TO KEEP LIGHTS ON UPON LOSS OF CONTROL. POWER
5. CASE LIGHTING TO BE CONTROLLED THROUGH LOCAL CONTROLLERS AT CASE

RMCS CONTROL OF SALES AREA LIGHTS

ON / OFF CONTROL _____ NO SCALE

DATE
JUN 2022

DEFENSE COMMISSARY AGENCY
DIRECTORATE OF ENGINEERING
FORT LEE, VIRGINIA - LACKLAND AFB, TEXAS

TITLE
RMCS CONTROL OF SALES AREA LIGHTS

REF.
REV.

DESIGN STANDARD
230916-01