



- NOTES:
1. ADD POWER CONDITIONERS WHERE NECESSARY FOR STABLE FUNCTION
  2. SEE DESIGN STANDARD 265100-01 FOR CONTINUATION
  3. POWER LIGHTS NORMALLY CLOSED TO KEEP LIGHTS ON UPON LOSS OF CONTROL POWER

**RMCS CONTROL OF EXTERIOR AREA LIGHTS**  
 ON / OFF CONTROL NO SCALE

DATE JUN 2022	DEFENSE COMMISSARY AGENCY DIRECTORATE OF ENGINEERING FORT LEE, VIRGINIA - LACKLAND AFB, TEXAS		DESIGN STANDARD
	TITLE RMCS CONTROL OF EXTERIOR SALES AREA LIGHTS	REF.	230916-02
		REV.	