



NOTES:

1. 23 09 16 TO FURNISH AND INSTALL ALL WORK NECESSARY TO ESTABLISH COMMUNICATION WITH RMCS AND CONTROL OF EQUIPMENT AS SPECIFIED.
2. RMCS TO FOLLOW SEQUENCE OF OPERATION FOR OPERATING WATER VALVES (IF ANY).
3. VALVES MAY ALSO BE OPERATED THROUGH AN APPLICATION SPECIFIC CONTROLLER LOCATED AT THE EQUIPMENT.

RMCS CONTROL FOR MOTORIZED WATER VALVES

NO SCALE

<p>DATE</p> <p>JUN 2022</p>	<p style="text-align: center;">DEFENSE COMMISSARY AGENCY DIRECTORATE OF ENGINEERING FORT LEE, VIRGINIA - LACKLAND AFB, TEXAS</p> <p>TITLE</p> <p style="text-align: center;">RMCS VALVE (TYPICAL)</p>	<p>DESIGN STANDARD</p> <p>230916-22</p> <p>REF.</p> <p>REV.</p>
-----------------------------	---	---