



NOTE:
ALSO APPLIES TO INSULATED SUCTION LINES AT THE FIRST
THREE SUSPENSION POINTS FROM THE COMPRESSOR.

**CLAMP ASSEMBLY FOR UN-INSULATED
REFRIGERANT LINE OR ELECTRICAL CONDUIT**

NO SCALE

DATE JUN 2022	DEFENSE COMMISSARY AGENCY DIRECTORATE OF ENGINEERING FORT LEE, VIRGINIA - LACKLAND AFB, TEXAS	DESIGN STANDARD 239000-05A
	TITLE CLAMP ASSEMBLY FOR INSULATED REFRIGERANT LINE	