



SUPPORT INTERVAL SCHEDULE	
REFRIGERATION PIPE SIZE	MAXIMUM INTERVAL
UP TO 7/8	5'-0"
1 1/8 TO 1 5/8	8'-0"
2 1/8 TO 2 5/8	10'-0"
3 1/8 TO 3 5/8	12'-0"
4 1/8	14'-0"
NOTE	
1. SMALLEST LINE ON RACK SHALL DETERMINE SUPPORT INTERVAL. 2. THIS DETAIL DOES NOT INCLUDE SEISMIC SUPPORT INFORMATION. PROVIDE SEISMIC EQUIPMENT SUPPORT IN ACCORDANCE WITH ALL APPLICABLE CODES AND MANUFACTURERS RECOMMENDATIONS.	

## REFRIGERATION PIPING SUPPORT

NO SCALE

DATE  JUN 2022	DEFENSE COMMISSARY AGENCY DIRECTORATE OF ENGINEERING FORT LEE, VIRGINIA - LACKLAND AFB, TEXAS		DESIGN STANDARD  239000-07A
	TITLE  OVERHEAD REFRIGERANT PIPE SUPPORT	REF.	
		REV.	