



NOTES:

PROVIDE DRIP PAN UNDER ALL NEW REFRIGERANT PIPING WHERE SST IS BELOW 0°F. OMIT PANS IN MECHANICAL ROOM.

WHERE CONFLICTS BETWEEN CONDENSATE PAN AND CEILING GRID SUSPENSION WIRING EXIST, PROVIDE SEAM IN CONDENSATE PAN OR RE-SUPPORT CEILING GRID.

REFRIGERATION PIPING CONDENSATE DRAIN PAN

NO SCALE

DATE JUN 2022	DEFENSE COMMISSARY AGENCY DIRECTORATE OF ENGINEERING FORT LEE, VIRGINIA - LACKLAND AFB, TEXAS		DESIGN STANDARD 239000-08
	TITLE REFRIGERATION PIPING CONDENSATE DRAIN PAN DETAIL	REF.	
		REV.	