

DESIGN CRITERIA

1. Related Sections: Section 26 05 00 applies.
2. Summary:
 - A. Provide manual motor starters on all 1/2 HP and smaller motors unless indicated otherwise by applicable Design Standard plates.
 - B. Starters and control equipment for non-refrigeration motors larger than 1/2 HP are furnished under Division 26
 - C. Connect automatic control and protective devices furnished under Division 26.
 - D. Starters: NEMA rated, utilizing class 20 overloads.

END OF SECTION