



OUTDOOR GENERATOR CONNECTION CABINET (EDIT)

BERTHOLD CATALOG #W12-5S-S2-8W-9 (OR EQUAL)
1200A, 480/277V, 3PH, 4W, 35KAIC (EDIT)

1,200 AMP (EDIT)
FUSED OUTDOOR
DISCONNECT

EXISTING

4 SETS OF 3 #350, #350N
#370 GROUND IN 3" C
(EDIT)

MOUNTING EARS
3" I.D. RUBBER BUSHINGS
FOR TEMPORARY CABLE ENTRY.

PROVISION ONLY ON FRONT
AND BOTTOM DOORS FOR
KIRK KEY INTERLOCK

DATE

JUN 2022

DEFENSE COMMISSARY AGENCY
DIRECTORATE OF ENGINEERING
FORT LEE, VIRGINIA - LACKLAND AFB, TEXAS

TITLE

GENERATOR CONNECTION BOX

REF.

REV.

DESIGN
STANDARD

260500-01