



NOTES:

- 1 SEAL INSIDE AND OUTSIDE OF NIPPLE WITH SILICONE FOR AIR TIGHT SEAL.
- 2 SEE ELECTRICAL LEGEND AND SYMBOLS ON DRAWINGS.
- 3 TO KEEP CORD OFF FLOOR, WIRE TIE EXCESS CORD IN LOOP ON UPPER SECTION OF CORD.

DATE	DEFENSE COMMISSARY AGENCY DIRECTORATE OF ENGINEERING FORT LEE, VIRGINIA - LACKLAND AFB, TEXAS		DESIGN STANDARD
JUN 2022	TITLE CEILING RECEPTACLE DETAIL MEAT PROCESSING AND WRAPPING ROOMS	REF.	262726-01
		REV.	