



KEYED NOTES:

- ① RMCS NORMALLY CLOSED CONTACTS. CONTACTS CYCLED BASED ON USER PROGRAMMABLE SCHEDULE. TYPICAL, NUMBER AS INDICATED ON THE CONTACTOR SCHEDULE.
- ② LIGHTING CONTACTOR(S) WITH ELECTRICALLY HELD CONTACTS. CONTACTOR(S) SHALL NOT BE LOCATED IN SALES AREA, ADMIN., NOR BREAK ROOM. SEE DRAWINGS/SCHEDULE FOR FEEDERS OR CIRCUITS DESIGNATED FOR CONTROL. TYPICAL, NUMBER AS INDICATED ON THE CONTACTOR SCHEDULE.
- ③ OFF-ON-AUTO SWITCH IN CONTACTOR COVER. TYPICAL, NUMBER AS SALES LIGHTING CONTACTORS.

DESIGNER: SHOW CONTACTORS AND SWITCHES LOCATIONS ON PLANS. DO NOT LOCATE CONTACTORS WHERE HUM AND NOISE WILL BE OBJECTIONABLE, SUCH AS SALES AREA, ADMIN., OR BREAKROOM. PROVIDE A LIGHTING CONTACTOR SCHEDULE (SEE D.S. 265100-02)

DATE	DEFENSE COMMISSARY AGENCY DIRECTORATE OF ENGINEERING FORT LEE, VIRGINIA - LACKLAND AFB, TEXAS		DESIGN STANDARD
JUN 2022	TITLE SALES AREA LIGHTING CONTROLS	REF.	265100-01
		REV.	