

# LIGHTING CONTACTOR SCHEDULE

MARK	NO. OF POLES	CONTACT AMP RATING	CONTACT VOLTAGE	COIL VOLTAGE	CONTROL SOURCE	CONTRACTOR LOCATION	DEVICE CONTROLLED
LC-1					1	4	SALES AREA 50%
LC-2					1		SALES AREA 50%
LC-3					1		CHECKOUT AREA
LC-4					1		SALES AREA TRACK, MASS DISPLAY, PRODUCE, DAIRY
LCXS					2		EXTERIOR SECURITY
LCXP					2		EXTERIOR PATRON PARKING
LCXE					2		EXTERIOR EMPLOYEE PARKING
LCXR					2		EXTERIOR RECEIVING POLE LIGHTS

**KEYED NOTES:**

- 1 RMCS CONTROLLED, SEE SALES AREA LIGHTING CONTROL DETAIL
- 2 SEE EXTERIOR LIGHTING CONTROL DETAIL
- 3 ELECTRICALLY HELD CONTACTS
- 4 TO MINIMIZE NOISE, CONTACTOR'S SHALL NOT BE MOUNTED IN ADMIN, BREAKROOM NOR SALES AREA

DATE

JUN 2022

DEFENSE COMMISSARY AGENCY  
DIRECTORATE OF ENGINEERING  
FORT LEE, VIRGINIA - LACKLAND AFB, TEXAS

TITLE

LIGHTING CONTACTOR SCHEDULE

REF.

REV.

DESIGN  
STANDARD

265100-02