



- NOTES:
1. AVOID SHARP BENDS IN BOTH THE COAX CABLE AND GROUND CONDUCTOR.
 2. GROUND PER NFPA 70, ARTICLE 810

DATE	DEFENSE COMMISSARY AGENCY DIRECTORATE OF FACILITIES FORT LEE, VIRGINIA - LACKLAND AFB, TEXAS		DESIGN STANDARD
JUN 2022	TITLE	FIRE ALARM TRANSMITTER ANTENNA DETAIL	283176-01
		REF.	
		REV.	