



300mm (12") DIA. NON-PERFORATED PVC, UP TO 200 CFM POWER  
 ROOF VENTILATOR LOCATED ON ROOF FAN SHALL RUN  
 CONTINUOUSLY AND BE MONITORED BY THE RMCS

NOTE:  
 MAINTAIN POSITIVE AIR FLOW IN VOID SPACE BETWEEN FREEZER WALL PANELS AND OTHER  
 WALL SURFACES. THE 4" DIAMETER VENT PIPES SHALL STUB UP 4" AFF. COVER OPEN ENDS OF  
 VENT PIPES WITH 11 GA. STAINLESS STEEL WIRE MESH (1/4" CENTER TO CENTER OF WIRES)

DATE	DEFENSE COMMISSARY AGENCY DIRECTORATE OF ENGINEERING FORT LEE, VIRGINIA - LACKLAND AFB, TEXAS		DESIGN STANDARD
	JUN 2022		
TITLE	INSULATED CONCRETE FREEZER FLOORS UNDERFLOOR VENTILATION SYSTEM		033050-01
	REF.	REV.	