

DESIGN CRITERIA

1. Related Sections: See Division 32 Section Concrete Paving Joint Sealants; Division 03 Section Cast-in-Place Concrete for joint fillers; Division 04 Section Unit Masonry for joint fillers and gaskets for control and expansion joints in unit masonry; Division 07 Section Firestopping; Division 08 Section Glazing for glazing sealants; Division 09 Section Resilient Tile Flooring for joint fillers in concrete floor slab; and Division 09 Section Gypsum Board for sealing perimeter joints of gypsum board partitions to reduce sound transmission.
2. This Section specifies elastomeric and latex joint sealants for applications indicated at beginning of Section, and continuous foam compression seals to fill voids between refrigerated display cases and adjacent wall surfaces. Refer to Design Standard Plate 10 15 00-01 and 10 15 00-02 07 92 00 - 1 and 07 92 00 - 2.
3. Control / contraction joints in exposed concrete floor slabs shall be filled with joint filler as specified in Division 03 Section Cast-In-Place Concrete.
4. Control / contraction joints in concrete floor surfaces receiving resilient floor tile covering shall be filled with latex patching or underlayment compound recommended by resilient flooring manufacturer.

END OF SECTION